



Caledonian IEC 60502 Cables www.caledonian-cables.com

marketing@caledonian-cables.com

600/1000V, PVC Insulated Cables according to IEC 60502-1 4C120

Four cores(Galvanized steel wire armoured)





APPLICATIONS

These cables are used for electricity supply in low voltage installation system, They are suitable forinstallation in indoors and outdoors, in cable ducts, under ground, in power and switching stations, localenergy distributions, industrial plants, where there is no risk of mechanical damage.

VOLTAGE RATING

600/1000V

CABLE CONSTRUCTION

Conductors: The conductors shall be either of Class 1 or Class 2 of plain or metal-coated annealed copper or of plain aluminium or aluminium alloy, or of Class 5 of plain ormetal-coated copper in accordance with IEC 60228. Insulation: PVC Insulation material and thickness shall be as per IEC 60502-1, PVC materialshall be Type A as per IEC 60502-1.

Assembly/ Inner Covering: The inner coverings may be extruded or lapped. For cables with circular cores, except cables with more than five cores, a lapped inner covering shall be permittedonly if the interstices between the cores are substantially filled. A suitable binderis permitted before application of an extruded inner covering. The materials usedfor inner coverings and fillers shall be suitable for the operating temperature of the cable and compatible with the insulating material. For halogen free cables, the innercovering and fillers shall also be halogen free compound.

Armou:Aluminum/galvanized steel/steel wires applied helically over the Inner Covering asper IEC 60502-1, or double aluminum/steel tapes and copper/tinned copper wirecan also be manufactured upon request.

Outer Sheath:Outer sheath shall be of extruded PVC Type ST1/ST2 as per IEC 60502-1,Polyethylene type ST3/ ST7, Halogen free compound ST8, Polychloroprene,chlorosulfonated polyethylene or similar polymers, type SE1 are also available onrequest.

Fire Performance of Cable Sheaths:Cables can be supplied with special flame retardant PVC outer sheath to complywith the flame test requirements of IEC 60332-3-22, IEC 60332-3-23 and IEC60332-3-24, Halogen Free material comply to IEC60754-1/2 and IEC 60684-2.

COLOUR CODE

Colour Code:Red, Yellow, Blue,Black

DIMENSION AND PARAMETERS



Caledonian

IEC 60502 Cables www.caledonian-cables.com

marketing@caledonian-cables.com

| No. of Cores × Cross- sectional Area | Conductor Diameter | Nominal Insulation Thickness | Nominal Thickness of Inner Covering | Nominal Sheath Thickness | Nominal Steel Wire Armour Diameter | Approx. Overall Diameter |
|--|-----------------------|------------------------------------|---|--------------------------------|--|--------------------------------|
| No.×mm² | mm | mm | mm | mm | mm | mm |
| 4×120 | 12.4 | 1.6 | 1.4 | 2.6 | 2.5 | 50.6 |