


Caledonian IEC 60502 Cables www.caledonian-cables.com

marketing@caledonian-cables.com

#### 600/1000V,XLPE Insulated Cables according to IEC 60502-1 2C95

Two cores(unarmoured)





# **APPLICATIONS**

These cables are used for electricity supply in low voltage installation system, They are suitable forinstallation in indoors and outdoors, in cable ducts, under ground, in power and switching stations, localenergy distributions, industrial plants, where there is no risk of mechanical damage

### **VOLTAGE RATING**

600/1000V

### CABLE CONSTRUCTION

Conductors: The conductors shall be either of Class 1 or Class 2 of plain or metal-coated annealed copper or of plain aluminium or aluminium alloy, or of Class 5 of plain ormetal-coated copper in accordance with IEC 60228. Insulation: XLPE material and thickness shall be as per IEC 60502-1, rated for 90°C continuous operation. Outer Sheath: Outer sheath shall be of extruded PVC Type ST1/ST2 as per IEC 60502-1, Polyethylene type ST3/ST7, Halogen free compound ST8, Polychloroprene, chlorosulfonated polyethylene or similar polymers, type SE1 are also available onrequest.

Fire Performance of Cable Sheaths:Cables can be supplied with special flame retardant PVC outer sheath to comply with the flame test requirements of IEC 60332-3-22, IEC 60332-3-23 and IEC 60332-3-24, Halogen Free material comply to IEC60754-1/2 and IEC 60684-2.

# COLOUR CODE

Colour Code (1) :Red,Black Colour Code (2) :Brown,Blue

#### DIMENSION AND PARAMETERS

No. of Cores × Cross-sectional Area	Conductor Diameter	Nominal Insulation Thickness	Nominal Sheath Thickness	Approx. Overall Diameter
No.×mm <sup>2</sup>	mm	mm	mm	mm
2×95	11.0	1.1	1.9	30.2