


600/1000V PVC Insulated, PVC Sheathed, Armoured Power Cables to IEC 60502(3Cores)

FGD400 1VVMV-R 3C120(CU/PVC/PVC/SWA/PVC 600/1000V Class 2)





APPLICATIONS

The cables are mainly used in power stations, mass transit underground passenger systems, airports,petrochemical plants, hotels, hospitals, and high-rise buildings.

STANDARDS

Basic design to IEC60502

FIRE PERFORMANCE

	Flame Retardance (Single Vertical Wire Test)	IEC 60332-1-2
--	--	---------------

VOLTAGE RATING

600/1000V

CABLE CONSTRUCTION

Conductor: Annealed copper wire, stranded according to IEC 60228 class 2.

Insulation: PVC/A according to IEC 60502-1.

Inner Covering: Extruded PVC or polymeric compound.

Armouring: Galvanized steel wire

Outer Sheath: Extruded PVC Type ST1/ST2 according to IEC 60502-1.

Outer Sheath Option: UV resistance, hydrocarbon resistance, oil resistance, anti rodent and anti termite properties can be offered as option. Compliance to fire performance standard (IEC 60332-1, IEC 60332-3, UL 1581, UL 1666 etc) depends on the oxygen index of the PVC compound and the overall cable design.LSPVC can also be provided upon request.

COLOUR CODE

Insulation Colour:Brown,black,grey Sheath Colour: Black (other colours upon request)

PHYSICAL AND THERMAL PROPERTIES

Maximum temperature range during operation (PVC): 70°C Maximum short circuit temperature (5 Seconds): 160°C(<=300 mm²); 140°C(>300 mm²)



www.caledonian-cables.com

marketing@caledonian-cables.com

Minimum bending radius: Circular copper conductors: 6 x Overall Diameter Shaped copper conductors: 8 x Overall Diameter

Electrical Properties

Conductor Operating Temperature: 70°C Ambient Temperature: 30°C

DIMENSION AND PARAMETERS

No. of Cores × Cross- sectional Area	Conductor Class	Nominal Insulation Thickness	Nominal Thickness of Inner Covering	Nominal Sheath Thickness	Nominal Steel Wire Armour Diameter	Nom. Overall Diameter	Approx. Weight
No.×mm ²		mm	mm	mm	mm	mm	kg/km
3x120	2	1.6	1.2	2.4	2.5	45.9	6677

Current-Carrying Capacities (Amp) according to BS 7671: 2008 table 4D4A

Conductor Cross- sectional Area	Ref. Method C One 1C cable, 1- phase a.c. or d.c.	Ref. Method C One 3C or 4C cable, 3-phase a.c.	Ref. Method D One 2C cable, 1- phase a.c. or d.c.	Ref. Method D One 3C or 4C cable, 3-phase a.c.	Ref. Method E One 2C cable, 1- phase a.c. or d.c.	Ref. Method E One 3C or 4C cable, 3-phase a.c.
mm²	А	А	A	A	А	A
120	310	267	231	192	336	290

Voltage Drop (Per Amp Per Meter) according to BS 7671: 2008 table 4D4B

Conductor Cross-sectional Area	-sectional Area 2C cable, d.c. 2C cable, 1-phase a.c.		3C or 4C cable, 3-phase a.c.	
mm²	mV/A/m	mV/A/m	mV/A/m	
120	0.36	r:0.38 x:0.155 z:0.41	r:0.33 x:0.135 z:0.35	



Rated voltage



IEC60502-1